

Regarding:
Door Access Control RFP R2223-06

AMENDMENT 1

issued 06/06/2023

1.0 DESCRIPTION OF GOODS AND/OR SERVICES

Items highlighted in yellow have been added &/or changed.

The Court (JBE) seeks an access control system for 41 doors.

- **20** Doors wireless electronic locks with battery supply and Wi-Fi connectivity for doors with no access path. Card Readers access.
- **21** Doors wired with card reader access.
- Controllers for wireless electronic locks on each floor.
- All wired card readers run back to nearest IDF.
- Must include all equipment, materials and installation including low voltage work, such as cable runs, terminations, and testing.
- Web-based controller.

****Contractor is to determine which doors are best served with wired or wireless equipment****

End of Amendment.