

# Bulk Asbestos Analysis

(EPA Method 40CFR, Part 763, Appendix E to Subpart E and EPA 600/R-93-116, Visual Area Estimation)  
NVLAP Lab Code: 101459-0

Nicklaus Engineering, Inc.  
Stacy Gutierrez  
1851 W. 24th St.  
Ste. 101  
Yuma, AZ 85364

**Client ID:** C1039  
**Report Number:** B324869  
**Date Received:** 11/02/21  
**Date Analyzed:** 11/04/21  
**Date Printed:** 11/04/21  
**First Reported:** 11/04/21

**Job ID/Site:** 21-0232 - El Centro Court House, Decorative Trim

**SGSFL Job ID:** C1039  
**Total Samples Submitted:** 3  
**Total Samples Analyzed:** 3

**Date(s) Collected:** 10/31/2021

Sample ID	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
<b>4</b>	12491987						
Layer: Grey Cementitious Material			<b>ND</b>				
Layer: Grey Coating		Chrysotile	<b>2 %</b>				
Layer: Paint			<b>ND</b>				
Total Composite Values of Fibrous Components:		<b>Asbestos (Trace)</b>					
Cellulose (Trace)							
<b>5</b>	12491988						
Layer: Grey Cementitious Material			<b>ND</b>				
Layer: Grey Coating		Chrysotile	<b>2 %</b>				
Layer: Paint			<b>ND</b>				
Total Composite Values of Fibrous Components:		<b>Asbestos (Trace)</b>					
Cellulose (Trace)							
<b>6</b>	12491989						
Layer: Grey Cementitious Material			<b>ND</b>				
Layer: Grey Coating		Chrysotile	<b>2 %</b>				
Layer: Paint			<b>ND</b>				
Total Composite Values of Fibrous Components:		<b>Asbestos (Trace)</b>					
Cellulose (Trace)							



Tad Thrower, Laboratory Supervisor, Hayward Laboratory

**Note:** Limit of Quantification ('LOQ') = 1%. 'Trace' denotes the presence of asbestos below the LOQ. 'ND' = 'None Detected'.

Analytical results and reports are generated by SGS Forensic Laboratories (SGSFL) at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by SGSFL to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by SGSFL. The client is solely responsible for the use and interpretation of test results and reports requested from SGSFL. SGSFL is not able to assess the degree of hazard resulting from materials analyzed. SGS Forensic Laboratories reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified. All samples were received in acceptable condition unless otherwise noted.